



本處傳真 OUR REF.: (9) in FP 206/1057
來函編號 YOUR REF.: SCF-6378
電子郵件 E-mail: <lcplc2@hkfsd.gov.hk>
圖文傳真 FAX: 852-2367 3631
電話 TEL NO.: 2733 7827

13 March 2007

16 MAR 2007

Wai Kong Fire Engineering Co., Ltd.
Unit B11, 4/F., Block B,
Tonic Industrial Centre,
19 Lam Hing Street,
Kowloon Bay,
Hong Kong.

Dear Sirs,

Acceptance of Water Control Valves

I refer to my interim reply of 29.12.2006 on the captioned subject.

Please be informed that the following pieces of equipment, which have been certified by Underwriters Laboratories Inc. (UL), are acceptable to this Department:-

- Manufacturer** : Dorot Valve Mfrs
- Type** : Special System Water Control Valves, Deluge Type
- i) **Model** : Model 30U deluge valves in the 2, 2.5, 3, 4, 6, 8, 10 and 12 in. sizes
- Rated Pressure** : 175 psig
- Testing Standard** : UL 260
- Supporting Document** : File EX6543 Project 03CA06310 issued by UL on 16.9.2004 and UL online certificate VLFT.EX6543 dated 17.8.2005.
- ii) **Model** : Model 68 deluge valves in the 2, 3, 4, 6, 8 and 10 in. sizes
- Rated Pressure** : 175 psig
- Testing Standard** : UL 260
- Supporting Document** : File EX6543 Project 04NK29992 issued by UL on 6.12.2004 and latest revised on 15.2.2005.

.../2

Please note that the above acceptance is valid subject to :-

- i) all conditions stipulated in the above-mentioned test reports being complied with; and
- ii) the installation conforming to FSD Circular Letter No. 2/94 Rules for Automatic Sprinkler Installations.

Yours faithfully,

(LAI Man-hin)
for Director of Fire Services

LMH/YCO/lcm
REF.: (9) in FP 206/1057