



VLFT.EX15233 Special System Water Control Valves, Deluge Type

[Page Bottom](#)

Special System Water Control Valves, Deluge Type

[See General Information for Special System Water Control Valves, Deluge Type](#)**DOROT ITALIA SRL**

EX15233

Dorot Italia via Carlo Dell'Acqua 7
20027 Rescaldina, MI ITALY

Pre-action Deluge type valves, Models 30U, and 30CU flanged grooved or threaded body end connections with control trims DE\EL, DE\EL-MR, DE\RC, DE\RC-MR, DE\RCL, DE\PORV, DE\PORV-MR, DE\EL\PORV, DE\EL\PORV-MR, DE\HM, DE\HM-MR, DE\HRV, DE\HRV-MR, DE\EL\HRV, DE\EL\HRV-MR, DE\RCE, DE\EL\PORV-DN and DE\EL\PORV-DN-MR rated pressure 375 psig, 2, 2.5, 3, 4, 6, 8 and 300 psig rated pressure in 10 and 12 in. size globe pattern for horizontal or vertical installation. For operation hydraulically, pneumatically, electrically, manually or combinations thereof. Manual or remote reset. The height of the hydraulic pilot line above the DE\HM valve is limited as shown in the manufacturer's installation instructions.

Pre-action Deluge type Valves, Model 30AU flanged grooved or threaded body end connections with control trims DE\EL, DE\EL-MR, DE\RC, DE\RC-MR, DE\RCL, DE\PORV, DE\PORV-MR, DE\EL\PORV, DE\EL\PORV-MR, DE\HM, DE\HM-MR, DE\HRV, DE\HRV-MR, DE\EL\HRV, DE\EL\HRV-MR, DE\RCE, DE\EL\PORV-DN and DE\EL\PORV-DN-MR rated pressure 375 psig, 2, 2.5, 3, 4, 6, 8 and 300 psig rated pressure in 10 and 12 in. size angle pattern. For operation hydraulically, pneumatically, electrically, manually or combinations thereof. Manual or remote reset. The height of the hydraulic pilot line above the DE\HM valve is limited as shown in the manufacturer's installation instructions.

Pressure Regulating Pre-action Deluge type Valves, Model 30U and 30AU flanged grooved or threaded body end connections with control trims DE\EL\PR, DE\RC\PR, DE\RCL\PR, DE\PORV\PR, DE\EL\PORV\PR, DE\HRV\PR, DE\EL\PORV\PR\DN, DE\EL\HRV\PR, DE\PORV\PR-MR, DE\EL\PORV\PR-MR, DE\EL\PORV\PR\DN-MR, DE\HRV\PR-MR, DE\EL\HRV\PR-MR rated pressure 375 psig in 2, 2.5, 3, 4, 6 and 8 in and 300 psig rated pressure in 10 and 12 inch sizes with globe or angle pattern for horizontal or vertical installation. For operation hydraulically, pneumatically, electrically, manually or combinations thereof. Manual or remote reset. The height of the hydraulic pilot line above the DE\HM valve is limited as shown in the manufacturer's installation instructions.

Pre-action Deluge type valves, Model 68 flanged or grooved body end connections rated pressure 375 psig 2, 2.5, 3, 4, 6, 8, and 10 in. size diaphragm type for horizontal or vertical installation with control trims DE\EL, DE\EL-MR, DE\RC, DE\RC-MR, DE\RCL, DE\PORV, DE\PORV-MR, DE\EL\PORV, DE\EL\PORV-MR, DE\HM, DE\HM-MR, DE\HRV, DE\HRV-MR, DE\EL\HRV, DE\EL\HRV-MR, DE\RCE, DE\EL\PORV-DN and DE\EL\PORV-DN-MR. Pressure Regulating Pre-action Deluge valves. Model 68 rated pressure 375 psig with control trims DE\EL\PR, DE\RC\PR, DE\RCL\PR, DE\PORV\PR, DE\EL\PORV\PR, DE\HRV\PR, DE\EL\HRV\PR, DE\EL\PORV\PR-DN, DE\PORV\PR-MR, DE\EL\PORV\PR-MR, DE\HRV\PR-MR, DE\EL\HRV\PR-MR, DE\EL\PORV\PR-DN-MR. For operation hydraulically, pneumatically, electrically, manually or combinations thereof. Manual or remote reset. The height of the hydraulic pilot line above the DE\HM valve is limited as shown in the manufacturer's installation instructions.

The Models 30U, 30AU, 30CU and 68 valves can be equipped with the following optional accessories: Hazardous location solenoid valves, Visual Position Indicator stem with or without Electric or Magnetic /Inductive type proximity/Limit Switch and Hazardous location proximity/Limit Switch.

Authorities having jurisdiction should be consulted before installation.

[Last Updated](#) on 2017-09-12[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2017 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2017 UL LLC".